

CHANGE LOG

Addendum F (5/15/26)

DISCIPLINE	ITEM #	SHEET/SPEC NUMBER	CHANGE DESCRIPTION
Civil		CO2.3	Road Width Updates
		CO2.5	Added Gate on Trash Enclosure, Reduce Gabion Wall by 3ft length.
		CO2.6	Add NO PARKING FIRE LANE sign
		CO2.7	Added Fire Sign, rolled curb callout, adjustment with drainage
		CO2.8	Adjustment of septic tank layout, rolled curb callout
		CO3.2	Added sewer general notes
		CO3.4	Specific size of pipe sleeve into concrete pedestal
		CO3.6	Added a Retaining Wall referencing a detail #4
		CO3.8	Added 6" Dry Hydrant, multiple small callout changes, bypass valve
		CO5.1	Added rolled curb detail, updated vertical curb detail
		CO5.2	Added Fire Lane Sign Detail
		CO6.4	6" Dry Hydrant Detail
		CO6.5	UV Light (Add E), only one 125 AMP panel now for whole bldg